



Choose certainty. Add value.

IT Security for control systems of ropeways

Dr. Thomas Störtkuhl Team Leader Industrial IT Security TÜV SÜD Rail April 2016

TÜV SÜD AG



Contact





Dr. Thomas Störtkuhl thomas.stoertkuhl@tuev-sued.de Phone: +49 89 5791-1930 Fax: +49 89 5791-2933

- Team leader Industrial IT Security
- 25 years experience in IT
- More than 15 years experience in information security
- Projects for companies; branches: critical infrastructures, automotive, production, administration, finance
- Certificates: CISSP, CISA, CISM, ISO/IEC 27001 Auditor

TÜV

Current security incidents ...



DIE SWELT	Hackers Reveal Nasty New Car
DIGITAL VERNETZTE PRODUKTION	AttacksWith Me Behind The
Industrie ist gegen Hacker schlecht gerüstet	Wheel (Video) This story appears in the August 12, 2013 issue of Forbes.
Bedrohung für die Industrie: Durch die Vernetzung von Maschinen wird die Produktion	The New York Times
zunehmend ein Sicherheitsrisiko. Derzeit eingesetzte Software hilft kaum gegen die künftigen Angriffe.	POLITICS
BBC BBC iD Menu - Search	Utilities Cautioned About Potential for a Cyberattack After Ukraine's
NEWS	By DAVID E. SANGER FEB. 29, 2016
	WASHINGTON — The Obama administration has warned the nation's power companies, water suppliers and transportation
Hack attack causes 'massive damage' at steel works	f Share networks that sophisticated cyberattack techniques used to bring down part of <u>Ukraine</u> 's power grid two months ago could easily be
© 22 December 2014 Technology	Tweet
	BloombergBusiness 1
heise Security News - Hintergrund Tools Foren Kontakt 🕑 🛐 🚳 🗠 🦄	
Security > News > 7-Tage-News > 2014 > KW 50 > Zugang über Umwege – Hacker nutzen Zulieferer als Einfallstor	Mysterious '08 Turkey
09.12.2014 09:16 « Vorige Nächste »	Pipeline Blast Opened
Zugang über Umwege – Hacker nutzen Zulieferer als Einfallstor	Now Cybonwar
Täglich greifen Hacker deutsche Firmen an. Einige haben ihre Sicherheitsvorkehru	ngen
deshalb in den vergangenen Jahren ausgeweitet. Doch die eigene Sicherheit liegt n mehr allein in den Händen der Unternehmen.	hicht by Jordan Robertson and Michael Riley
TÜV SÜD AG 16-03-30	Slide 3



Information Security is the preservation of (see ISO/IEC 27000)

Confidentiality

The property that information is not made available or disclosed to unauthorized individuals, entities, or processes.

Integrity

The property of protecting the accuracy and completeness of assets.

Availability

The property of being accessible and usable upon demand by an authorized entity.

and for control systems also

• **Safety** *Freedom from unacceptable risk.* (siehe IEC 61508)

has to be considered.

TÜV SÜD AG



Control system for ropeways (simplified)





TÜV®

Threats to the control system infrastructure of ropeways





TÜV®



- Denial-of-Service: no remote maintenance
 => long interruption for service
- Manipulated SCADA: change of parameters and settings of control system
 - => no normal operation
 - => system may be stopped
- Encryption of data
 attempted extortions
- Manipulated control
 => system may be stopped
 => safety might be manipulated





People, Process, Technology







Holistic approach







Security Risk

Operational

TÜV®

Host Layer Network

Layer

Layer

- Security policies and guidelines
- Physical protection (physical zoning)
- Network segregation (zones and conduits)
- Need-to-Know: Restriction of access to components, systems, zones and conduits
- Minimum installation: hardening of components
- Living processes
- Skilled and trained employees

cf. Homeland Security (2009) Recommended Practice: Improving Industrial Control Systems Cybersecurity with Defense-In-Depth Strategies figure 5

Must be considered: Roles



Source: IEC 62443 standard

TÜV SÜD AG

TÜV®

Continuous Improvement: Security is a process





Contact



Frank Seyfried frank.seyfried@tuev-sued.de Phone: +49 89 5791-2430 Fax: +49 89 5791-2470

Dr. Thomas Störtkuhl thomas.stoertkuhl@tuev-sued.de

Phone: +49 89 5791-1930 Fax: +49 89 5791-2933

TÜV SÜD Westendstr. 199 80686 Munich Germany

www.tuev-sued.com



